Certified translation from English





Declaration of conformity

No. E8A 003649 0008 Version 01

Zhejiang CHINT Certificate holder:

> Instrument & Meter Co., Ltd. Wenzhou Bridge Industrial Zone

325603 Yueging

PEOPLE'S REPUBLIC OF CHINA

Product name:Power meters

(Smart Power Sensor)

Model(s): DTSU666-H, DTSU666-H 250A/50mA

Product Description" Voltage Rating: 3*230/400 V

> Rated current: 100 A/40 mA (for DTSU666-H)

250 A/50 mA (for DTSU666-H 250A/50mA)

Protection class:

Tested in accordance with: EN 61326-1:2013

EN 61326-2-1:2013

This Declaration of Conformity is issued on a voluntary basis in accordance with EMC Directive 2014/30/EU. It confirms that the equipment listed complies with all essential directives and is based on technical specifications available at the time of issue. Applies only to the specific sample provided for testing and certification. See also the notes on the back.

Research Report No.: 64713180045802

(Tony Liu) [illegible signature]. Date, 2019-05-10

I hereby certify the conformity of the above translation with a copy of the document in English.

Jan Przemyslaw Kubik, a sworn translator of English, entered in the list of sworn translators, kept by the Minister of Justice, under number TP/5/16.

Number in the repertory:

1567/2020 Bielsko-Biala.

16.12.2020.

Jan Przemyslaw Electronically signed by Jan Przemyslaw Kubik Date: Kubik

2020.12.16 08:11:56

+01'00'

Page 1 of 1

Once the necessary technical documentation and EU declaration of conformity have been prepared, the required CE marking can be affixed to the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU directives must be complied with.

