

Certificate of Conformity

Certificate Number: CN-PV-230322

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant:	Shenzhen Growatt New Energy Co., Ltd. 4-13/F, Building A, Sino-German (Europe) Industrial Park, Hangcheng Ave, Bao'an District, Shenzhen, China.
Product:	Hybrid Inverter/AC Coupled Inverter
Ratings & Principle Characteristics:	See appendix of Certificate of Conformity
Model:	MID 11KTL3-XA, MID 12KTL3-XA, MID 13KTL3-XA, MID 15KTL3-XA, MID 17KTL3-XA, MID 20KTL3-XA, MID 25KTL3-XA, MID 30KTL3-XA, MID 11KTL3-XH, MID 12KTL3-XH, MID 13KTL3-XH, MID 15KTL3-XH, MID 17KTL3-XH, MID 20KTL3-XH, MID 25KTL3-XH, MID 30KTL3-XH, MID 8000TL3-XH L, MID 10KTL3-XH L, MID 12KTL3-XH L, MID 15KTL3-XH L GROWATT
Brand Name<s>:	
Product Complies with:	IEC/EN 62109-1:2010 (First Edition) Safety of Power Converter for use in Photovoltaic Power Systems Part 1: General requirements IEC/EN 62109-2:2011 Safety of Power Converter for use in Photovoltaic Power Systems Part 2: Particular requirements for inverters EN IEC 62477-1:2022, Safety requirements for power electronic converter systems and equipment Part 1: General Low Voltage Directive 2014/35/EU
Certificate Issuing Office Name & Address:	Intertek Testing Services Ltd. Shanghai West Area, 2 nd Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
Test Report No.<s>:	230315062ZU-001, 230315062GZU-002, 230315062GZU-003

Additional information in Appendix.



Signature

Certification Manager: Grady Ye
Date: 09 June 2023



PRD N° 306B

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230322.

Model	MID 11KTL3-XH	MID 12KTL3-XH	MID 13KTL3-XH	MID 15KTL3-XH	MID 17KTL3-XH
Max.PV voltage	1100Vdc				
MPPT voltage	160-1000Vdc				
Max.input current	32/32A				
PV Isc	40/40A				
Nominal output voltage	3W/N/PE, 230/400 a.c.V				
Nominal output Frequency	50/60Hz				
Max.output current	18.3A	20A	21.7A	25A	28.3
Max. output power	11KW	12KW	13KW	15KW	17KW
Max. apparent power	12.1KVA	13.2KVA	14.3KVA	16.5KVA	18.7KVA
Power factor range	0.8Leading~0.8Lagging				
Safety level	Class I				
Ingress Protection	IP 66				
Operation Ambient Temperature	-25°C - +60°C				
Software version	DN1.0				

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230322.

Model	MID 20KTL3-XH	MID 8000TL3-XH L	MID 10KTL3-XH L	MID 12KTL3-XH L	MID 15KTL3- XH L
Max.PV voltage	1100Vdc				
MPPT voltage	160-1000Vdc	160-850Vdc			
Max.input current	32/32A	32/32/32A			
PV Isc	40/40A	40/40/40A			
Nominal output voltage	3W/N/PE, 230/400a.c.V	3W/PE, 133/230 a.c.V			
Nominal output Frequency	50/60Hz				
Max.output current	33.3A	21.0A	26.3A	31.5A	39.4A
Max. output power	20KW	8KW	10KW	12KW	15KW
Max. apparent power	22KVA	8KVA	10KVA	12KVA	15KVA
Power factor range	0.8Leading~0.8Lagging				
Safety level	Class I				
Ingress Protection	IP 66				
Operation Ambient Temperature	-25°C - +60°C				
Software version	DN1.0				

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230322.

Model	MID 25KTL3-XH	MID 30KTL3-XH
Max.PV voltage	1100Vdc	
MPPT voltage	160-1000Vdc	
Max.input current	32/32/32A	
PV Isc	40/40/40A	
Nominal output voltage	3W/N/PE, 230/400a.c.V	
Nominal output Frequency	50/60Hz	
Max.output current	41.6A	45.5A
Max. output power	25KW	30KW
Max. apparent power	27.5KVA	30KVA
Power factor range	0.8Leading~0.8Lagging	
Safety level	Class I	
Ingress Protection	IP 66	
Operation Ambient Temperature	-25°C - +60°C	
Software version	DN1.0	

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230322.

Model	MID 11KTL3- XA	MID 12KTL3- XA	MID 13KTL3- XA	MID 15KTL3- XA	MID 17KTL3- XA
Battery voltage range	600V-980V				
Type of Battery	Lithium				
Max.input/output current	16.7/16.7a.c.A	18.2/18.2a.c.A	19.7/19.7a.c.A	22.7/22.7a.c.A	25.8/25.8a.c.A
Nominal output voltage	3W/N/PE, 230/400a.c.V				
Nominal output Frequency	50/60Hz				
Max.output current	16.7A	18.2A	19.7A	22.7A	25.8A
Max. output power	11KW	12KW	13KW	15KW	17KW
Power factor range	0.8Leading~0.8Lagging				
Safety level	Class I				
Ingress Protection	IP 66				
Operation Ambient Temperature	-25°C - +60°C				
Software version	DN1.0				

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230322.

Model	MID 20KTL3-XA	MID 25KTL3-XA	MID 30KTL3-XA
Battery voltage range	600V-980V		
Type of Battery	Lithium		
Max.input/output current	30.3/30.3a.c.A	37.9/37.9a.c.A	45.5/45.5a.c.A
Nominal output voltage	3W/N/PE, 230/400a.c.V		
Nominal output Frequency	50/60Hz		
Max.output current	30.3A	37.9A	45.5A
Max. output power	20KW	25KW	30KW
Power factor range	0.8Leading~0.8Lagging		
Safety level	Class I		
Ingress Protection	IP 66		
Operation Ambient Temperature	-25°C - +60°C		
Software version	DN1.0		

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.